

Primary System Design Summary

Date: 09/18/2017

Lot #	Block #	Treatment Level	Depth of Limiting Layer	Land Slope %	Soil Texture	Soil Hydrolic	Primary System Type	Min. Sand Lift (in)
1	1	C	34	3	Silt Loam	0.5	Mound	12
2	1	C	24	4	Silt Loam	0.5	Mound	12
3	1	C	22	4	Silt Loam	0.5	Mound	18
4	1	C	40	5	Silt Loam	0.5	At Grade	
5	1	C	34	6	Silt Loam	0.5	Mound	12
6	1	C	28	3	Silt Loam	0.5	Mound	12
7	1	C	42	11	Silt Loam	0.5	At Grade	
8	1	C	24	10	Silt Loam	0.5	Mound	12
9	1	C	28	6	Silt Loam	0.5	Mound	12
10	1	C	11	5	Silt Loam	0.5	Mound	36
11	1	C	12	4	Silt Loam	0.5	Mound	24
12	1	C	12	6	Silt Loam	0.5	Mound	24
13	1	C	21	2	Silt Loam	0.5	Mound	18
14	1	C	38	3	Silt Loam	0.5	At Grade	
15	1	C	16	9	Silt Loam	0.5	Mound	24
16	1	C	6	11	Silt Loam	0.5	Mound	36
17*	1	C	15	12	Silt Loam	0.5	Mound	24
18	1	C	37	8	Silt Loam	0.5	At Grade	
19	1	C	39	4	Silt Loam	0.5	At Grade	
20	1	C	50	6	Silt Loam	0.5	Trench	
21	1	C	41	3	Silt Loam	0.5	At Grade	
22	1	C	19	3	Silt Loam	0.5	Mound	18
23	1	C	53	4	Silt Loam	0.5	Trench	0
24	1	C	10	5	Silt Loam	0.5	Mound	36
25	1	C	21	4	Silt Loam	0.5	Mound	18
26	1	C	30	2	Silt Loam	0.5	Mound	12
27	1	C	10	2	Silt Loam	0.5	Mound	36
28	1	C	43	7	Silt Loam	0.5	Trench	
29	1	C	8	4	Silt Loam	0.5	Mound	36
30	1	C	10	4	Silt Loam	0.5	Mound	36

*Lot 17 is an approved site. Septic Permit #19-88

ROAD				
Soil Boring #	Depth of Limiting Layer	Land Slope %	Soil Texture	Soil Hydrolic
33	10	6	Silt Loam	0.5
34	7	8	Silt Loam	0.5
35	36	8	Silt Loam	0.5
36	25	9	Silt Loam	0.5
37	18	10	Silt Loam	0.5
38	19	7	Silt Loam	0.5
39	33	6	Silt Loam	0.5
40	10	3	Silt Loam	0.5
41	17	3	Silt Loam	0.5
42	23	8	Silt Loam	0.5
43	25	6	Silt Loam	0.5
44	14	4	Silt Loam	0.5
45	26	2	Silt Loam	0.5