

## Fenstra CUP

- Recommend the driveway is constructed to conform to the Decorah Edge Ordinance and is the minimum amount of disturbance necessary.
- If there is a need to conduct construction dewatering of either storm water or ground water in volumes exceeding 10,000 gallons per day, or one million gallons per year, for constructing the facilities, then a DNR Water Appropriation Permit is required for the dewatering. A DNR water appropriation permit may be applied for on-line at: <https://webapps11.dnr.state.mn.us/mpars/public/authentication/login>.